

POLICY:	WATER SUPPLY – MINIMUM PRESSURE STANDARDS
DATE ADOPTED:	Director Engineering Services' Report #9.3.4 Council 18 October 2023 Resolution No. ORD2023-317 Director Corporate Services & Finance's Report #1 Policy 5 December 2012 Council 6 February 2013 Minute Book No. 11477
ORIGINAL ADOPTION:	Director Engineering Services Report #4 Council 18 August 2004 Minute Book No. 9314, 9315
FILE REFERENCE:	37.00152
OBJECTIVE	To provide a minimum standard for water pressure for future development

The minimum static head required to the highest point on each lot is 30m, calculated when the reservoirs are one-third depleted.

The main shall also be capable of delivering a peak instantaneous demand of 0.15L/s to each lot, at a minimum head of 15m measured at the property water meter, with the service reservoirs two-thirds depleted.