

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 13/01/2019
Summary of results for: January
Number of measurements taken: 5
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	31	2.8	2	7.4	0.27	5
Mean	2	72	3.8	2	7.5	0.54	8
Median	2	69	3.5	2	7.4	0.43	7
Maximum	3	110	5.9	3	7.6	1.10	11
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
Minimum	2	500	0.6	2	7.2	0.06	14
Mean	2	1000	1.2	2	7.5	0.15	116
Median	2	900	1.2	2	7.5	0.15	116
Maximum	2	1700	1.7	2	7.9	0.24	218

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
Minimum	2	300	0.5	2	7.3	0.04	7
Mean	2.5	812	1.0	2	7.6	0.14	75
Median	2.5	300	1.0	2	7.6	0.14	75
Maximum	3	2700	1.5	2	7.9	0.23	143

Point 1

Date	Volume Discharged
	kL
Minimum	811
Mean	8,158
Median	7,986
Maximum	13,124

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 12/03/2019
Summary of results for: February
Number of measurements taken: 4
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	8	3.4	2	7.3	0.56	5
Mean	2	51	6.7	2	7.5	0.81	7
Median	2	23	6.2	2	7.4	0.73	7
Maximum	3	150	11.2	2	8.0	1.20	11
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
Minimum	2	430	0.6	2	7.8	0.08	20
Mean	2	1500	0.6	2	7.8	0.08	20
Median	2	1585	0.6	2	7.8	0.08	20
Maximum	2	2400	0.6	2	7.8	0.08	20

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
Minimum	2	33	0.5	3	7.8	0.10	19
Mean	2	543	0.5	3	7.8	0.10	19
Median	2	570	0.5	3	7.8	0.10	19
Maximum	2	1000	0.5	3	7.8	0.10	19

Point 1

Date	Volume Discharged
	kL
Minimum	6,775
Mean	9,076
Median	8,327
Maximum	16,450

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 14/04/2019
Summary of results for: March
Number of measurements taken: 4
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	3.1	2	7.4	0.25	5
Mean	3	12	4.0	2	7.4	0.45	5
Median	2	10	4.0	2	7.4	0.46	5
Maximum	4	26	4.8	2	7.5	0.64	5
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	3	560	0.7	2	7.9	0.06	12
Mean	3	990	0.7	2	7.9	0.06	12
Median	3	850	0.7	2	7.9	0.06	12
Maximum	3	1700	0.7	2	7.9	0.06	12

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	67	0.7	2	8.0	0.06	13
Mean	2	249	0.7	2	8.0	0.06	13
Median	2	230	0.7	2	8.0	0.06	13
Maximum	2	470	0.7	2	8.0	0.06	13

Point 1

Date	Volume Discharged
	kL
Minimum	6,684
Mean	8,837
Median	8,447
Maximum	16,939

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 10/05/2019
Summary of results for: April
Number of measurements taken: 4
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	4.6	2	7.3	0.37	5
Mean	2	6	5.1	2	7.4	0.40	8
Median	2	3	4.9	2	7.3	0.40	7
Maximum	2	16	6.2	2	7.4	0.44	14
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	700	0.4	2	8.0	0.07	5
Mean	2	900	0.4	2	8.0	0.07	5
Median	2	750	0.4	2	8.0	0.07	5
Maximum	2	1400	0.4	2	8.0	0.07	5

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	180	0.4	2	7.9	0.06	7
Mean	2	298	0.4	2	7.9	0.06	7
Median	2	315	0.4	2	7.9	0.06	7
Maximum	2	380	0.4	2	7.9	0.06	7

Point 1

Date	Volume Discharged
	kL
Minimum	6,801
Mean	8,150
Median	7,996
Maximum	10,012

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 11/06/2019
Summary of results for: May
Number of measurements taken: 5
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	4.9	2	7.2	0.27	5
Mean	2	70	5.8	2	7.3	0.31	5
Median	2	19	5.4	2	7.3	0.30	5
Maximum	2	210	6.8	2	7.4	0.37	7
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	33	0.7	2	7.3	0.05	6
Mean	2	621	0.7	2	7.3	0.05	6
Median	2	620	0.7	2	7.3	0.05	6
Maximum	2	1200	0.7	2	7.3	0.05	6

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	67	0.1	2	7.9	0.05	10
Mean	2	161	0.1	2	7.9	0.05	10
Median	2	200	0.1	2	7.9	0.05	10
Maximum	2	230	0.1	2	7.9	0.05	10

Point 1

Date	Volume Discharged
	kL
Minimum	6,837
Mean	8,748
Median	8,501
Maximum	12,884

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 2/07/2019
Summary of results for: June
Number of measurements taken: 4
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	5.5	2	7.1	0.24	5
Mean	2	4	6.1	2	7.1	0.33	5
Median	2	3	5.9	2	7.1	0.27	5
Maximum	2	6	7.0	3	7.2	0.52	6
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	84	0.4	2	7.7	0.05	5
Mean	2	421	0.4	2	7.7	0.05	5
Median	2	450	0.4	2	7.7	0.05	5
Maximum	2	700	0.4	2	7.7	0.05	5

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	74	0.3	2	7.9	0.05	5
Mean	2	414	0.3	2	7.9	0.05	5
Median	2	91	0.3	2	7.9	0.05	5
Maximum	2	1400	0.3	2	7.9	0.05	5

Point 1

Date	Volume Discharged
	kL
Minimum	7,519
Mean	8,738
Median	8,635
Maximum	10,222

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 9/08/2019
Summary of results for: July
Number of measurements taken: 5
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	4.9	2	7.11	0.25	4
Mean	2	9	7.3	2	7.17	0.30	5
Median	2	3	5.8	2	7.17	0.30	5
Maximum	3	25	14.3	2	7.26	0.39	5
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	380	0.4	2	7.8	0.05	9
Mean	2	904	0.4	2	7.8	0.05	9
Median	2	670	0.4	2	7.8	0.05	9
Maximum	2	1500	0.4	2	7.8	0.05	9

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	29	0.2	2	8.0	0.05	5
Mean	2	74	0.2	2	8.0	0.05	5
Median	2	77	0.2	2	8.0	0.05	5
Maximum	2	120	0.2	2	8.0	0.05	5

Point 1

Date	Volume Discharged
	kL
Minimum	0
Mean	8,166
Median	8,448
Maximum	9,709

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 6/09/2019
 Summary of results for: August
 Number of measurements taken: 4
 Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	7.9	2	6.96	0.26	5
Mean	2	30	8.8	2	7.07	0.31	6
Median	2	27	8.3	2	7.08	0.31	5
Maximum	3	63	10.8	2	7.16	0.34	7
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	380	0.4	2	7.8	0.05	9
Mean	2	904	0.4	2	7.8	0.05	9
Median	2	670	0.4	2	7.8	0.05	9
Maximum	2	1500	0.4	2	7.8	0.05	9

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	26	0.4	2	8.1	0.05	5
Mean	2	63	0.4	2	8.1	0.05	5
Median	2	32	0.4	2	8.1	0.05	5
Maximum	2	160	0.4	2	8.1	0.05	5

Point 1

	Volume Discharged
	kL
Minimum	7,640
Mean	8,403
Median	8,452
Maximum	9,187

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published:
Summary of results for:
Number of measurements taken:
Monitoring Frequency Required:

9/10/2019
September
4
Weekly

**Point 1
Discharge to Macquarie River**

	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	7.5	2	7.02	0.29	5
Mean	2	13	10.2	2	7.18	0.51	5
Median	2	5	8.5	2	7.16	0.40	5
Maximum	2	41	16.4	2	7.37	0.95	5
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	81	0.4	2	8.1	0.70	9
Mean	2	468	0.4	2	8.1	0.70	9
Median	2	485	0.4	2	8.1	0.70	9
Maximum	2	820	0.4	2	8.1	0.70	9

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Minimum	2	52	0.3	2	8.2	0.78	13
Mean	2	102	0.3	2	8.2	0.78	13
Median	2	73	0.3	2	8.2	0.78	13
Maximum	2	210	0.3	2	8.2	0.78	13

Point 1

	Volume Discharged
	kL
Minimum	7,722
Mean	8,673
Median	8,323
Maximum	14,992

Summary of Units of Measure

mg/L = milligrams per litre
CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 7/11/2019
Summary of results for: October
Number of measurements taken: 5
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	6.4	2	7.1	0.25	5
Mean	2	6	9.3	2	7.2	0.46	5
Median	2	3	9.9	2	7.2	0.48	5
Maximum	2	13	11.8	2	7.4	0.67	6
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Minimum	3	250	1.0	2	7.5	0.05	10
Mean	3	2774	1.0	2	7.5	0.05	10
Median	3	4000	1.0	2	7.5	0.05	10
Maximum	3	5200	1.0	2	7.5	0.05	10

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Minimum	2	120	0.3	2	7.7	0.04	7
Mean	2	248	0.3	2	7.7	0.04	7
Median	2	160	0.3	2	7.7	0.04	7
Maximum	2	570	0.3	2	7.7	0.04	7

Point 1

	Volume Discharged kL
Minimum	7,255
Mean	8,112
Median	8,001
Maximum	10,521

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 5/12/2019
Summary of results for: November
Number of measurements taken: 4
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	7.2	2	7.3	0.36	5
Mean	2	10	8.7	2	7.4	0.44	5
Median	2	5	8.9	2	7.4	0.42	5
Maximum	2	28	9.8	2	7.6	0.54	5
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Minimum	3	250	1.0	2	7.5	0.05	10
Mean	3	2774	1.0	2	7.5	0.05	10
Median	3	4000	1.0	2	7.5	0.05	10
Maximum	3	5200	1.0	2	7.5	0.05	10

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Minimum	2	120	0.6	2	7.9	0.05	11
Mean	2	520	0.6	2	7.9	0.05	11
Median	2	480	0.6	2	7.9	0.05	11
Maximum	2	1000	0.6	2	7.9	0.05	11

Point 1

	Volume Discharged kL
Minimum	2,367
Mean	6,878
Median	7,036
Maximum	8,585

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Data Published: 7/01/2020
Summary of results for: December
Number of measurements taken: 4
Monitoring Frequency Required: Weekly

**Point 1
Discharge to Macquarie River**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
Minimum	2	3	4.6	2	7.5	0.29	5
Mean	2	5	7.3	2	7.5	0.42	5
Median	2	3	7.1	2	7.5	0.43	5
Maximum	3	9	10.4	2	7.5	0.54	5
Exceedance	No	No	No	No	No	No	No

**Point 3
Environmental Monitoring 50m Downstream of Point 1**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Minimum	2	200	1.0	2	7.7	0.08	13
Mean	2	1008	1.0	2	7.7	0.08	13
Median	2	915	1.0	2	7.7	0.08	13
Maximum	2	2000	1.0	2	7.7	0.08	13

**Point 4
Environmental Monitoring 50m Upstream of Point 1**

	BOD mg/L	Faecal Coliforms CFU/100mL	Total Nitrogen mg/L	Oil and Grease mg/L	pH	Total Phosphorus mg/L	Total Suspended Solids mg/L
Minimum	2	100	0.8	2	7.9	0.05	7
Mean	2	575	0.8	2	7.9	0.05	7
Median	2	600	0.8	2	7.9	0.05	7
Maximum	2	1000	0.8	2	7.9	0.05	7

Point 1

	Volume Discharged kL
Minimum	4,465
Mean	6,468
Median	6,576
Maximum	8,408

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres