

**Bathurst Regional Council**  
**Waste Water Treatment Works**  
**EPA Licence Number 1647**

Date Sample Taken: 4/01/2023  
 Date Sample Received at Laboratory: 5/01/2023  
 Date Data Received from Laboratory: 11/01/2023  
 Date Data Published: 24/01/2023  
 Data Published within 14 days: Yes

**Point 1- Weekly Sample**  
**Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
<b>Limit</b>	<b>30</b>	<b>600</b>	<b>20.0</b>	<b>10</b>	<b>6.5 - 8.5</b>	<b>2.00</b>	<b>30</b>
4/01/2023	11	250	6.3	2	7.53	0.19	5
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly Sample**  
**Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
4/01/2023	NR	3300	NR	NR	NR	NR	NR

**Point 4 - Weekly Sample**  
**Environmental Monitoring Upstream of Wastewater Treatment Works**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
4/01/2023	NR	1900	NR	NR	NR	NR	NR

**Summary of Units of Measure**

mg/L = milligrams per litre  
 CFU/100mL = colony forming units per 100 millilitres  
 NR = Not required

