

**Bathurst Regional Council**  
**Waste Water Treatment Works**  
**EPA Licence Number 1647**

Date Sample Taken: 22/02/2023  
 Date Sample Received at Laboratory: 23/02/2023  
 Date Data Received from Laboratory: 2/03/2023  
 Date Data Published: 9/03/2023  
 Data Published within 14 days: Yes

**Point 1- Weekly Sample**  
**Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
<b>Limit</b>	<b>30</b>	<b>600</b>	<b>20.0</b>	<b>10</b>	<b>6.5 - 8.5</b>	<b>2.00</b>	<b>30</b>
22/02/2023	2	53	12.5	2	7.57	0.72	9
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly Sample**  
**Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
22/02/2023	2	1100	0.7	2	7.8	0.05	25

**Point 4 - Weekly Sample**  
**Environmental Monitoring Upstream of Wastewater Treatment Works**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
22/02/2023	2	1200	0.6	3	7.8	0.05	35

**Summary of Units of Measure**

mg/L = milligrams per litre  
 CFU/100mL = colony forming units per 100 millilitres  
 NR = Not required

