

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

17/03/2023

Data Published within 14 days:

Yes

Point 1 - Final Effluent

| Date | Volume Discharged |
|------------|-------------------|
| | kL/d |
| 7/03/2023 | 8,886 |
| 8/03/2023 | 8,935 |
| 9/03/2023 | 9,027 |
| 10/03/2023 | 9,025 |
| 11/03/2023 | 8,564 |
| 12/03/2023 | 8,472 |
| 13/03/2023 | 8,058 |

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL