

Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647

Date Data Published:

21/04/2023

Data Published within 14 days:

No

Note

Discharge data was originally posted within 14 days on 03/04/2023, however an error was subsequently discovered on one of the daily volume discharge amounts.

All data on this report is correct.

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
28/03/2023	17,617*
29/03/2023	18,281*
30/03/2023	11,492
31/03/2023	12,906
1/04/2023	10,501
2/04/2023	10,383
3/04/2023	10,154

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day

*Rainfall

28/03/2023:13mm

29/03/2023:18mm



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL