

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

14/09/2023

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
5/09/2023	8464
6/09/2023	8753
7/09/2023	9238
8/09/2023	8821
9/09/2023	10963
10/09/2023	9241
11/09/2023	8607

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL