

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

3/11/2023

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
24/10/2023	8,661
25/10/2023	72
26/10/2023	15,104
27/10/2023	10,241
28/10/2023	8,963
29/10/2023	8,183
30/10/2023	8,534

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day

