

**Bathurst Regional Council  
Waste Water Treatment Works  
EPA Licence Number 1647**

**Date Data Published:**

**30/11/2023**

**Data Published within 14 days:**

**Yes**

**Point 1 - Final Effluent**

<b>Date</b>	<b>Volume Discharged</b>
	<b>kL/d</b>
21/11/2023	7,877
22/11/2023	11,047
23/11/2023	12,450
24/11/2023	3,510
25/11/2023	9,682
26/11/2023	9,151
27/11/2023	9,192

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

**Summary of Units of Measure**

kL/d = kilolitres per day



**SUSTAINABLE BATHURST**  
**A BETTER FUTURE**  
AN INITIATIVE OF BATHURST REGIONAL COUNCIL