

Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647

Date Data Published:

8/12/2023

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
28/11/2023	9,821
29/11/2023	9,919
30/11/2023	17,898*
1/12/2023	12,096
2/12/2023	11,153
3/12/2023	9,734
4/12/2023	9,343

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day

* Rainfall

21.4mm on 27/11/2023

11.0mm on 28/11/2023

20.0 mm on 29/11/2023

4.0mm on 30/11/2023



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL