

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

16/02/2024

Data Published within 14 days:

Yes

Point 1 - Final Effluent

| Date | Volume Discharged |
|------------|-------------------|
| | kL/d |
| 6/02/2024 | 9,671 |
| 7/02/2024 | 16,450 |
| 8/02/2024 | 9,563 |
| 9/02/2024 | 8,576 |
| 10/02/2024 | 8,928 |
| 11/02/2024 | 7,994 |
| 12/02/2024 | 8,589 |

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL