

**Bathurst Regional Council  
Waste Water Treatment Works  
EPA Licence Number 1647**

**Date Data Published:**

**18/04/2024**

**Data Published within 14 days:**

**Yes**

**Point 1 - Final Effluent**

| <b>Date</b> | <b>Volume Discharged</b> |
|-------------|--------------------------|
|             | <b>kL/d</b>              |
| 9/04/2024   | 10,716                   |
| 10/04/2024  | 10,095                   |
| 11/04/2024  | 9,162                    |
| 12/04/2024  | 9,902                    |
| 13/04/2024  | 9,151                    |
| 14/04/2024  | 8,216                    |
| 15/04/2024  | 8,995                    |

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

**Summary of Units of Measure**

kL/d = kilolitres per day



**SUSTAINABLE BATHURST**  
**A BETTER FUTURE**  
AN INITIATIVE OF BATHURST REGIONAL COUNCIL