

**Bathurst Regional Council  
Waste Water Treatment Works  
EPA Licence Number 1647**

**Date Data Published:**

**7/08/2024**

**Data Published within 14 days:**

**Yes**

**Point 1 - Final Effluent**

Date	Volume Discharged
	kL/d
30/07/2024	12,845
31/07/2024	11,932
1/08/2024	12,039
2/08/2024	11,504
3/08/2024	11,299
4/08/2024	10,372
5/08/2024	10,731

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

**Summary of Units of Measure**

kL/d = kilolitres per day



**SUSTAINABLE BATHURST**  
**A BETTER FUTURE**  
AN INITIATIVE OF BATHURST REGIONAL COUNCIL