

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

6/09/2024

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
27/08/2024	10,633
28/08/2024	10,561
29/08/2024	10,389
30/08/2024	9,180
31/08/2024	9,738
1/09/2024	10,020
2/09/2024	9,364

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day

