

**Bathurst Regional Council  
Waste Water Treatment Works  
EPA Licence Number 1647**

**Date Data Published:**

**16/09/2024**

**Data Published within 14 days:**

**Yes**

**Point 1 - Final Effluent**

Date	Volume Discharged
	kL/d
3/09/2024	9,216
4/09/2024	9,497
5/09/2024	8,595
6/09/2024	8,364
7/09/2024	8,337
8/09/2024	8,876
9/09/2024	8,436

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

**Summary of Units of Measure**

kL/d = kilolitres per day



**SUSTAINABLE BATHURST**  
**A BETTER FUTURE**  
AN INITIATIVE OF BATHURST REGIONAL COUNCIL