

**Bathurst Regional Council  
Waste Water Treatment Works  
EPA Licence Number 1647**

**Date Data Published:**

**6/03/2025**

**Data Published within 14 days:**

**Yes**

**Point 1 - Final Effluent**

Date	Volume Discharged
	<b>kL/d</b>
25/02/2025	9,181
26/02/2025	8,624
27/02/2025	8,530
28/02/2025	8,309
1/03/2025	7,415
2/03/2025	7,717
3/03/2025	8,612

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

**Summary of Units of Measure**

kL/d = kilolitres per day



**SUSTAINABLE BATHURST**  
**A BETTER FUTURE**  
AN INITIATIVE OF BATHURST REGIONAL COUNCIL