## Bathurst Regional Council Waste Water Treatment Works EPA Licence Number 1647

Date Sample Taken:26/02/2025Date Sample Received at Laboratory:27/02/2025Date Data Received from Laboratory:4/03/2025Date Data Published:6/03/2025Data Published within 14 days:Yes

Point 1- Weekly Sample

**Discharge to Macquarie River** 

= 100 ma 0 quan 0 quan 0 ma 0 quan 0 ma 0 quan 0 ma 0 quan 0 ma 0 quan 0 q								
Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	рН	Total Phosphorus	Total Suspended Solids	
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L	
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30	
26/02/2025	2	15	5.2	2	7.5	0.53	5	
Exceedance	No	No	No	No	No	No	No	

## Point 3 - Weekly/Monthly Sample

**Environmental Monitoring 50m Downstream of Point 1** 

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	рН	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
26/02/2025	NR	1100	NR	NR	NR	NR	NR

## Point 4 - Weekly/Monthly Sample

**Environmental Monitoring Upstream of Wastewater Treatment Works** 

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	рН	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
26/02/2025	NR	500	NR	NR	NR	NR	NR

## **Notes**

mg/L = milligrams per litre

CFU/100mL = colony forming units per 100 millilitres

Monitoring and Recording Conditions: Point 1 - All pollutants monitored weekly. Points 3 & 4 - Faecal Coliforms monitored weekly, all other pollutants monitored monthly.

NR = Not required

